

CERTIFICATE OF COMPLIANCE

Certificate Number 20160422-R3749 |
Report Reference R3749 |
Issue Date 2016-April-22 |

Issued to: ISOLATEK INTERNATIONAL |
41 FURNACE ST
STANHOPE, NJ 07874 |

This is to certify that representative samples of SPRAY-APPLIED FIRE-RESISTANCE MATERIALS |
See next page for Models |

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Rapid Rise Fire Tests of Protection Materials for Structural Steel, UL 1709 |

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160422-R3749 |
Report Reference R3749 |
Issue Date 2016-April-22 |

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

At this time ISOLATEK® Type M-II, TG, and MII/P is covered by UL Follow-Up and Inspection Label Service and each bag supplied contains the appropriate UL Label.

Isolatek Trade Names in Western Hemisphere	Corresponding UL Type Designation	Isolatek Trade Names Outside The Western Hemisphere
CAFCO® FENDOLITE® M-II	Type M-II	ISOLATEK® Type M-II
CAFCO® FENDOLITE® TG	Type TG	ISOLATEK® Type TG
CAFCO® FENDOLITE® M-II/P	Type M-II/P	ISOLATEK® Type M-II/P

Type M-II (investigated for exterior use) for use in Design Nos. XR704, XR729, XR730.

Type M-II/P (investigated for exterior use) for use in Design No. XR723, XR725.

Type M-II and M-II/P may be trowel applied provided the Type M-II and M-II/P is first mixed with and pumped through standard application equipment as outlined in the manufacturer's application instructions. The minimum thickness and minimum in-place density of the Type M-II and M-II/P stated in the individual designs shall be maintained.

Type TG (investigated for exterior use) for use in Design No. XR704, XR729, XR730.

UL LLC does not keep record of the trade names under which the manufacturer markets a given product. However, when a manufacturer produces more than one product under a given product category, the products are differentiated by a type designation agreeable to the product manufacturer and UL LLC. This type designation shall appear in the proximity of the Classification Marking.

In addition, it should be understood that the Classification Marking of UL LLC on the product is the only method provided by UL LLC to identify products produced under its Classification and Follow-Up Service Program.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

